From: Megan Moir [mailto:mmoir@burlingtonvt.gov]

Sent: Sunday, August 17, 2014 3:51 PM

To: Myers, Jack **Cc:** Scott Gustin **Subject:** FAHC

Hi Jack,

I am largely without cell/wifi coverage while on vacation.

However, I did want to convey to you and Scott Gustin and the BCB – that I had a chat with Bill Nedde and confirmed that the impervious (both redeveloped and new) will receive full 2002 VSWMM treatment in the North Campus pond, with the modification/enlargement of the forebay.

Thus, I am not overly concerned with the stormwater management for this project. I would still like to know if FAHC is planning on including some green infrastructure components for the project. I am not going to make these a requirement per se of the project and Chapter 26 compliance (I still need to see full EPSC plans prior to earth disturbance).

Perhaps a better use of the projects investment would be to find some other stormwater improvement(s) – such as stabilization of the goat path that heads down from the FAHC area to Colchester Avenue – or perhaps FAHC would want to invest in a project that treats some other untreated impervious that drains to Centennial Brook to leverage the project. That sort of thing will have to be discussed when I return (and/or perhaps the BCB can suggest some ideas).

Again, I would love to see any intentional use of permeable pavers etc – but not in a forced way that necessarily requires UDs etc.

Hope that helps. MJM

Please note that our email domain has changed to @burlingtonvt.gov; please DELETE mmoir@ci.burlington.vt.us in your address books as it will not work. My new email address is below.

Megan Moir, CPESC, CPSWQ

Stormwater Program Manager
Burlington Public Works Department
C (802) 734.4595
P (802) 540.1748

Email: mmoir@burlingtonvt.gov/DPW/

facebook: http://www.facebook.com/BTVDPW

twitter: @btvdpw

Office Address:

234 Penny Lane Burlington, VT 05401 (in the Water Treatment building near the Moran Plant)

Mailing: PO Box 878

Burlington, VT 05402